

BUILDING SAFETY CERTIFICATE

No. 11/Camp/23b

Dated: 26/07/2023

Certified that the existing building M.N.B. Memorial Public School (name of the building or premises) at Nasirpur Math, Ballia, U.P. (address) comprised of Zero basement(s) and Block II & III (upper floors) owned/occupied by M.N.B. Memorial Public School, Nasirpur Math, Ballia, U.P. (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of 26/07/23 (A.E./RES Ballia) (Name of Department/ Govt.) on 26/07/23 (date of inspection) in the presence of Om. Pr. Singh (Manager) (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes h.t. XII (X/ XII) with effect from 26/07/23 for a period of 05 years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
- 3.
- 4.

Issued on 26/07/23 at RES - PWD Ballia U.P. by

* Strike out whichever is not applicable.

Signature with Seal: अध्यासी अभियन्ता 26.7.23

Name: बलिया (उपप) RS

Designation: अध्यासी RS

Name & Address of Department/ Office: _____

(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

कार्यालय अधिशासी अभियन्ता

प्रान्तीय खण्ड , लो0नि0वि0 , बलिया।

पत्रांक 048/2021 /2022-23

दिनांक:- 14/05/2022

प्रबन्धक ,

एम0एन0बी0 मेमोरियल पब्लिक स्कूल

नसीरपुर मठ, कोटवा नारायणपुर,

बलिया।

विषय:- विद्यालय भवन नेशनल बिल्डिंग कोड में प्राविधानित सुरक्षा मानकों के अनुरूप निर्मित किये जाने के सम्बन्ध में ।

संदर्भ: आपका पत्र -शून्य दिनांक :- 06.04.2022

उपरोक्त विषयगत संदर्भित पत्र के क्रम में एवं इस विकास खण्ड में कार्यरत सहायक अभियन्ता एवं अवर अभियन्ता के जाँच दिनांक 18.04.2022 के आधार पर प्रमाणित किया जाता है कि विद्यालय के भवन का निर्माण सुरक्षा मानकों के अनुरूप किया गया है।

संलग्नक- उक्तवत्।

अधिशासी अभियन्ता

प्रान्तीय खण्ड-लो0नि0वि0

बलिया।

जांच प्रमाण-पत्र

एम०एन०बी० मेमोरियल पब्लिक स्कूल नसीरपुर मठ कोटवा नारायनपुर, जनपद- बलिया के भवन का निरीक्षण किया गया। निरीक्षणोपरान्त भवन की निम्नांकित मदें नेशनल बिल्डिंग कोड के अनुरूप पायीं गयीं।

Sl. No	Items	Standard	Specification	Remarks
1	Height	3.6M	N.B.C. 2005 colum 12.18.1.1	3.30M
2	Bathroom Height	2.1M	N.B.C. Clause- 12.4.1	2.10 M
3	Open space around the Building	6.0 M	N.B.C. Clause- 8.3.1	Satisfactory
4	College Building area	1.80 ha	N.B.C. Clause 5.5.1(b) iii	Satisfactory
5	Parking area	0.30 ha	N.B.C. Clause 5.5.1 (b) ii(d)	Satisfactory
6	Height of Plinth	0.45 M	N.B.C. Clause- 12.1.1	0.45 M
7	Stair Width	1.50 M	N.B.C. Clause- 12.18.1.1	0.80 M
8	Lighting and Ventilation room	1/10 floor area	N.B.C. Clause- as per N.B.C. 2005 Clause- 15.1.2	Satisfactory
9	Fire and life safety	Certified by PHO Ballia	-	
10	Roofs	R.C.C. Flate Roof	as per N.B.C. 2005 Clause 12.19.1	R.C.C. Flate Roof
11	Structure	R.C.C. Column and Beam	as per N.B.C. 2005 Clause- 12.19.1	R.C.C. Column and beam

सहायक अभियन्ता
निर्माण खण्ड, लो०नि०वि०
बलिया

Manager
M.N.B. Memorial Public School
Nasirpurmath, Ballia (U.P.)

Principal
M.N.B. Memorial Public School
Nasirpur Math, Ballia (U.P.)