

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/112/23

Dated: 12-07-2023

It is certified that an inspection team headed by
Dr. Amit Kumar M.O CHC

(Name of Officers with designation) from
C.H.C. NARHI BALLIA U.P.

(Name of Department/ Office) inspected the
M.N.B. MEMORIAL PUBLIC SCHOOL, NASIRPURMATH BALLIA

(Name & Address of the school) on12/07/2023.....(date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of01 YEAR.....

Signature with Seal:

Name :

Designation :

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To MANAGER

M.N.B. MEMORIAL PUBLIC SCHOOL
.....

NASIRPURMATH BALLIA UP
.....

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT PUBLIC HEALTH LABORATORY AZAMGARH

REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Email: -dphlazamgarh@gmail.com

Phone (05462)265141

Name & Address of Sender :-	M.N.B. MEMORIAL PUBLIC SCHOOL NASIRPUR MATH, BALLIA (U.P.) 277501			
Sender's Letter No. & Date :-	Dt: - 12/07/2023			
Laboratory Reference No. :-	10549-55			
Date of Collection :-	12/07/2023			
Date of Arrival at Laboratory :-	12/07/2023			
Date of Commencing Examination :-	12/07/2023			
Sr. No.	Particular of Water Samples	Result of Analysis – Most Probable Number per 100 ml		
		Coli forms	Thermo tolerant Coli Forms	E. Coli
1	Drinking Water sample before R.O. Filter	>16	03	---
2	Drinking Water sample after R.O. Filter	0	---	---

Remark: - Above water sample No.1 is unfit and Sample No.2 is fit for drinking purposes However it they can be used, only after proper treatment, chlorination and retesting bacteriological to ascertain its / their fitness for drinking purposes.

Note: - Above water sample were not collected by this laboratory.


R. No. :- 1689031

Dt. 12/07/2023

Rs. 1050/-

Report Outward No. 2672

Date: - 13-07-23


Junior Scientific Officer
District Public Health Laboratory
Azamgarh.U.P.